

Partner: Crestron
Model: KNX
Device Type: (Logic)



GENERAL INFORMATION:

SIMPLWINDOWS NAME:	"Crestron KNX 4 Byte v3.2"
CATEGORY:	System control
VERSION:	V3.2
SUMMARY:	This macro represents one 4 Byte KNX data type.
GENERAL NOTES:	<p>PLEASE CAREFULLY READ THE KNX GATEWAY MANUAL BEFORE PROGRAMMING.</p> <p>This macro represents one 4 byte KNX data type. The macro is assigned a gateway ID to link it to a KNX IO module. The KNX IO module defines the Gateway type (CGEIB-IP or CI-KNX) that will be used to communicate with the KNX system.</p> <p>A KNX ID is assigned by filling in the parameter field "ID". Depending on the selected Gateway type on the KNX IO module a different format needs to be used.</p> <p>CI-KNX:</p> <p>The CI-KNX uses Object IDs that can be found in ETS in the parameter section for CI-KNX. I.e. if CI-KNX Object ID 1 added to the same group address as the 1 bit object that switches a light then the ID parameter on this module should contain "1".</p> <p>The CI-KNX supports up to 250 data type modules connected to one KNX IO module.</p> <p>CGEIB-IP:</p> <p>The CGEIB-IP uses group address as it is stated in the KNX software. I.e. if your group address is "12/3/255", you copy this exact sequence in the module's "Group Address" parameter. The parameter also allows 2-level group addresses.</p> <p>The CGEIB-IP supports up to 500 data type modules connected to one KNX IO module.</p>
CRESTRON HARDWARE REQUIRED:	3-Series processor
SETUP OF CRESTRON HARDWARE:	<p>The demo program was written for a CP3.</p> <p>The CGEIB-IP is controlled via TCP/IP. Port: 10001.</p> <p>The CI-KNX is controlled via TCP/IP. Port: 12004.</p>
VENDOR FIRMWARE:	CGEIB-IP: V7.03 CI-KNX: N/A
VENDOR SETUP:	CGEIB-(IP)/CI-KNX connected to the KNX bus
CABLE DIAGRAM:	Standard ethernet cable.

Partner: Crestron
Model: KNX
Device Type: (Logic)


CONTROL:

Poll_Value	D	Pulse to retrieve the current state.
Value_HighBytes	A	Analog value representing the two high bytes of the 4 Byte value.
Value_LowBytes	A	Analog value representing the two Low bytes of the 4 Byte value.
Send_Value	D	Pulse to set the 4 Byte value composed out the analog signals Value_HighBytes and Value_LowBytes.

FEEDBACK:

Initialization_is_Complete	D	High to indicate that the module is ready to be used.
Value_HighBytes_Analog	A	Analog value representing the two high bytes of the 4 Byte value.
Value_LowBytes_Analog	A	Analog value representing the two Low bytes of the 4 Byte value.
[Signed_Value_Text]	S	The textual representation of the signed 4 byte value.
[Unsigned_Value_Text]	S	The textual representation of the unsigned 4 byte value.
[FP_Value_Text]	S	The textual representation of the floating point 4 byte value.

PARAMETERS:

Gateway ID	Num	This ID should match with one of the Gateway IDs defined on the Crestron KNX IO modules in the program.
ID	S	The KNX data type ID. See general notes.

Partner: Crestron
Model: KNX
Device Type: (Logic)



TESTING:	
OPS USED FOR TESTING:	CP3: V. 1.501.2867.24563
SIMPL WINDOWS USED FOR TESTING:	V.4.07.03
CRESTRON DB USED FOR TESTING:	V. 64.00.001.00
DEVICE DB USED FOR TESTING:	V. 87.05.001.00
SAMPLE PROGRAM:	"Crestron KNX v3.2 CP3 Demo"
REVISION HISTORY:	V. 3.1 Fixed communication bug in the IO module. Fixed bug for sending the time of the Crestron system to the KNX system. V. 3.2 Added 3 byte data type module Fixed bug for CI-KNX 4 byte and 6 byte data types Updated logic for recovering the connection after a communication failure.