

**Partner: Lutron**  
**Model: HomeWorks QSX**  
**Device Type: Lighting**



## GENERAL INFORMATION

|                                    |  |
|------------------------------------|--|
| <b>SIMPLWINDOWS NAME:</b>          | Lutron HomeWorks QSX OpenCloseStop Fan Control v1.3  |
| <b>CATEGORY:</b>                   | Lighting, HVAC, Shades   |
| <b>VERSION:</b>                    | 1.3  |
| <b>SUMMARY:</b>                    | This module provides monitor and control capability for a Zone component as part of a Lutron HomeWorks QSX solution.   |
| <b>GENERAL NOTES:</b>              | This module interacts with a single component, if multiple components need to be managed, one module can be added for each component in the solution. This module requires one instance of the Lutron HomeWorks QSX Command Processor module to register with. |
| <b>CRESTRON HARDWARE REQUIRED:</b> | Crestron 3-Series or 4-Series processor.   |
| <b>SETUP OF CRESTRON HARDWARE:</b> | N/A  |
| <b>VENDOR FIRMWARE:</b>            | 23.08.14f000   |
| <b>VENDOR SETUP:</b>               | Lutron HomeWorks QSX Processor   |

**Partner: Lutron**  
**Model: HomeWorks QSX**  
**Device Type: Lighting**

**PARAMETER:****Command\_Processor\_ID**

Setting indicates the identifier of the Command Processor module this module registers with. A single program can contain multiple lighting modules where multiple Lutron processors are involved.

**Zone\_Href\_ID**

Setting indicates the reference identifier for the zone this OpenCloseStop control belongs to.

Example: for zone href: /Zone/1399, enter the value 1399 in the parameter field.



**Partner: Lutron**  
**Model: HomeWorks QSX**  
**Device Type: Lighting**

**FEEDBACK:****Is\_Initialized**

D

High indicates the module is initialized. The module is initialized when all component state information has been updated in the module to reflect current component state.

**Partner: Lutron**  
**Model: HomeWorks QSX**  
**Device Type: Lighting**

**TESTING:**

|   |   |
|---|---|
| <b>OPS USED FOR TESTING:</b>            | CP3 1.603.4242.34642<br>CP4 2.8000.00017  |
| <b>SIMPL WINDOWS USED FOR TESTING:</b>  | 4.22  |
| <b>CRES DB USED FOR TESTING:</b>        | 217.05  |
| <b>DEVICE DATABASE:</b>                 | 200.260   |
| <b>SYMBOL LIBRARY USED FOR TESTING:</b> | 1184  |
| <b>SAMPLE PROGRAM:</b>                  | Lutron HomeWorks QSX v1.3 Demo IP.smw   |
| <b>REVISION HISTORY:</b>                | v1.2 – Initial Release<br>v1.3 – Corrected for errors when inputs are triggered before module is initialized. |