





GENERAL INFORMATION			
SIMPLWINDOWS NAME:	Lutron RadioRA 3 Fan Control v1.1		
CATEGORY:	Lighting		
VERSION:	1.1		
SUMMARY:	This module provides monitor and control capability for a Fan component as part of a Lutron RadioRA 3 solution.		
GENERAL NOTES:	This module interacts with a single Fan component, if multiple lighting components need to be managed, one module can be added for each component in the solution. This module requires one instance of the Lutron RadioRA 3 Command Processor module to register with.		
CRESTRON HARDWARE REQUIRED:	Crestron 3-Series or 4-Series processor.		
SETUP OF CRESTRON HARDWARE:	N/A		
VENDOR FIRMWARE:	21.02.08f000		
VENDOR SETUP:	Lutron RadioRA 3 Processor		







PARAMETER:	
Command_Processor_ID	Setting indicates the identifier of the Command Processor module this module registers with. A single program can contain multiple lighting modules where multiple Lutron processors are involved.
Zone_Href_ID	Setting indicates the reference identifier for the zone this fan control belongs to. Example: for zone href: /Zone/1399, enter the value 1399 in the parameter field.







CONTROL:		
FanSpeed_Off	D	Pulse to turn the fan off.
FanSpeed_Low	D	Pulse to set the fan to low speed.
FanSpeed_Medium	D	Pulse to set the fan to medium speed.
FanSpeed_MediumHigh	D	Pulse to set the fan to medium-high speed.
FanSpeed_High	D	Pulse to set the fan to high speed.







FEEDBACK:		
ls_Initialized	D	High indicates the module is initialized. The module is initialized when all component state information has been updated in the module to reflect current component state.
FanSpeed_Is_Off	D	High indicates the fan is off.
FanSpeed_Is_Low	D	High indicates the fan is set to low speed.
FanSpeed_Is_Medium	D	High indicates the fan is set to medium speed.
FanSpeed_Is_MediumHigh	D	High indicates the fan is set to medium-high speed.
FanSpeed_Is_High	D	High indicates the fan is set to high speed.







TESTING:

OPS USED FOR TESTING: CP3 1.603.4242.34642

CP4 2.8000.00017

SIMPL WINDOWS USED FOR TESTING: 4.22

CRES DB USED FOR TESTING: 217.05

DEVICE DATABASE: 200.260

SYMBOL LIBRARY USED FOR TESTING: 1184

SAMPLE PROGRAM: Lutron RadioRA 3 v1.1 Demo IP.smw

v1.0 – Initial Release

v1.1 – Corrected for errors when inputs are triggered before module is initialized