

**Partner: Lutron**  
**Model: MyRoom XC**  
**Device Type: Lighting**



## GENERAL INFORMATION

<b>SIMPLWINDOWS NAME:</b>	Lutron MyRoom XC CCO Zone Control v1.0
<b>CATEGORY:</b>	Lighting, HVAC, Shades
<b>VERSION:</b>	1.0
<b>SUMMARY:</b>	This module provides monitor and control capability for a CCO Zone component as part of a Lutron MyRoom XC solution.
<b>GENERAL NOTES:</b>	This module interacts with a single CCO Zone component, if multiple CCO Zone components need to be managed, one module can be added for each component in the solution. This module requires one instance of the Lutron MyRoom XC Command Processor module to register with.
<b>CRESTRON HARDWARE REQUIRED:</b>	Crestron 4-Series processor
<b>SETUP OF CRESTRON HARDWARE:</b>	N/A
<b>VENDOR FIRMWARE:</b>	24.02.17f000
<b>VENDOR SETUP:</b>	Lutron MyRoom XC Processor

**Partner: Lutron**  
**Model: MyRoom XC**  
**Device Type: Lighting**

**PARAMETER:****Command\_Processor\_ID**

Setting indicates the identifier of the Command Processor module this module registers with. A single program can contain multiple zone modules where multiple Lutron processors are involved.

**Zone\_Href\_ID**

Setting indicates the reference identifier for the zone this zone control belongs to.  
Example: for zone href: /Zone/1399, enter the value 1399 in the parameter field.

**Partner: Lutron**  
**Model: MyRoom XC**  
**Device Type: Lighting**



**CONTROL:**

CCOLevel_Open	D	Pulse to open a CCO level.
CCOLevel_Close	D	Pulse to close a CCO level.

**Partner: Lutron**  
**Model: MyRoom XC**  
**Device Type: Lighting**

**FEEDBACK:**

<b>Is_Initialized</b>	D	High indicates the module is initialized. The module is initialized when all component state information has been updated in the module to reflect current component state.
<b>CCOLevel_Is_Open</b>	D	High indicates the CCO level is open.
<b>CCOLevel_Is_Closed</b>	D	High indicates the CCO level is closed.

**Partner: Lutron**  
**Model: MyRoom XC**  
**Device Type: Lighting**

**TESTING:**

<b>OPS USED FOR TESTING:</b>	CP4 2.8003.00056
<b>SIMPL WINDOWS USED FOR TESTING:</b>	4.30
<b>CRES DB USED FOR TESTING:</b>	225.05
<b>DEVICE DATABASE:</b>	200.350
<b>SYMBOL LIBRARY USED FOR TESTING:</b>	1205
<b>SAMPLE PROGRAM:</b>	Lutron MyRoom XC v1.0 Demo IP.smw
<b>REVISION HISTORY:</b>	v1.0 – Initial Release